STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	15G098	A. BUILDING **02** B. WING _____	R **03/27/2015**

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
COMMUNITY ALTERNATIVES SW IN	**10707 BERNADETTE DR** **EVANSVILLE, IN 47725**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
{K 000}	INITIAL COMMENTS A Post Survey Revisit (PSR) to the Life Safety Code Recertification Survey conducted on 01/28/15 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.470(j). Survey Date: 03/27/15 Facility Number: 000637 Provider Number: 15G098 AIM Number: 100234000 Surveyor: Lex Brashear, Life Safety Code Specialist At this PSR survey, Community Alternatives SW IN was found in compliance with Requirements for Participation in Medicaid, 42 CFR Subpart 483.470(j), Life Safety from Fire and the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC) 2000 Edition, Chapter 32, New Residential Board and Care Occupancies This one story facility was sprinklered. The facility has a fire alarm system with hard wired smoke detectors in the corridor, common living areas, and all client sleeping rooms. The facility has a capacity of eight and had a census of seven at the time of this survey. Calculation of the Evacuation Difficulty Score (E-Score) using NFPA 101A, Alternative Approaches to Life Safety, Chapter 6, rated the facility Prompt with an E-Score of 1.28. Quality Review by Dennis Austill, Life Safety Code Specialist on 03/31/15.	{K 000}		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE | TITLE | (X6) DATE

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	15G098	A. BUILDING **02** B. WING _____	R **03/27/2015**

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
COMMUNITY ALTERNATIVES SW IN	**10707 BERNADETTE DR** **EVANSVILLE, IN 47725**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE